



# INCERT CERTIFICATE C-060-1664/A



Issued 24-11-2023 Replaces C-060-1664  
Expiry date 24-11-2029 Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: Motion detector (white)  
Trademark: Ajax  
Type designation: MotionCam S PhOD Jeweller  
Hardware / Software: Cam.004.MBR.001v3, CAM.004.PIR.001v0 / 7.58.XX.XX  
Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: AJAX SYSTEMS MANUFACTURING, LIMITED LIABILITY COMPANY  
Address: Sklyarenka, 5,  
City: 04073 Kyiv  
Country: Ukraine

This certificate is granted to:

Name of the certificate holder: Ajax Systems Cyprus Holdings Ltd.  
Address: Ifigeneias 17  
City: 2007 Nicosia  
Country: CY

Ron Scheepers  
Managing director

*This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.*

# CERTIFICATE

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



**Remarks and observations**

The following conditions are applicable:

Category: Wireless PIR detector

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: C

The x visible in the sw version stands for a digit that can change in case of minor changes.

The certified version is recorded in the certification file together with any reported minor changes.

Factory location:

AJAX SYSTEMS MANUFACTURING, LIMITED LIABILITY COMPANY

Sklyarenka, 5,

Kyiv

Ukraine

Product inspection location:

ARAS Security

Thomas Edisonweg, 5

Drunen

Netherlands

**Documentation lodged for this INCERT certificate**

## Test Reports:

- Kiwa Nederland B.V.: P000321563-001-Ver 5.00, 16 October 2023
- Czech Metrology Institute, Brno: 8551-PT-E0139-22, 18 July 2022
- Kiwa Nederland B.V.: P000273777-001-Ver. 4.00, 15 November 2023
- Electrotechnical testing institute: 221737-01/01, 24 August 2022
- Testalarm Praha, Ltd.: 2022 0203, 19 September 2022
- Abegu, A.s.: P/22/01/39, 26 August 2022
- VZLU TEST, a.s.: P-VZLUTEST-161/22, 08 August 2022

## Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

T 031+A1+A2 August, 2022

**Applied Standards**

EN 50130-5	June, 2011
EN 50131-5-3	March, 2017
EN 50131-6	October, 2017
EN 50131-1+A1+A2+A3	June, 2020
EN 50131-2-2	December, 2021
EN 50130-4+A1	October, 2014

**The product as described in this certificate includes the following type designations**

- Product description: Motion detector (white)
- Trademark: Ajax
- Type designation: MotionCam S PhOD Jeweller
- Hardware version: Cam.004.MBR.001v3, CAM.004.PIR.001v0
- Software version: 7.58.XX.XX
  
- Product description: Motion detector (black)
- Trademark: Ajax
- Type designation: MotionCam S PhOD Jeweller
- Hardware version: Cam.004.MBR.001v3, CAM.004.PIR.001v0
- Software version: 7.58.XX.XX